

The device

EXHAUSTO SERIES VEX 4000

a product of
Exhausto A/S
Odensevej 76
DK 5550 Langeskov

conforms the hygiene requirements of the guideline
VDI 6022 sheet 1 (January 2018) Ventilation and
indoor-air quality; Hygiene requirements for ventilation
and air-conditioning systems and units.

The conformity inspection was passed by sample sets from the production
at Exhausto A/S in Langeskov.

Additionally Installation and User Instructions have been checked.

Audit period: October 2019 – March 2020

The test parameters and results are available on the test report
8366.001VEX4000p1 of 12 March 2020.

This certificate also attests the conformity to the hygiene requirements
of VDI 3803 (February 2010) at the time of inspection. The certificate is
valid for identical devices until February 2023, subject to any changes to
the design or materials used.

Essen, 12 March 2020



Hans Joachim Oldenburg
Site Manager

